Commonwealth of Pennsylvania
Uniform Construction Code
Review and Advisory Council

PENNSYLVANIA UNIFORM CONSTRUCTION CODE
ICC CODE CHANGES OF 2015 RECOMMENDATION FORM

Date Submitted:	2/8/18
Proposer's Name	David Kulina, R.A.
Company Affiliation (if any):	Engel Architects, LLC
Address:	1854 Lincoln Hwy East Lancaster, PA 17602
Telephone:	717-392-8021
Email:	david@engelarch.com
ICC Code:	IPC 2015
ICC Code Change Number :	
Code Section(s):	403.2 (IBC 2902.2)
This is a Recommendation:	☒ To Adopt the Change ☐ To Not Adopt the Change
For the Following Reasons: (Provide Details Below)	☐ Health Safety and Welfare ☐ Technical Feasibility ☒ Economic and Financial Impacts ☐ Other (Specify Below)

Detailed reasons for your recommendation. Provide relevant data to support your position when possible.

Recommend adding the following exemption:

4. Separate facilties shall not be required in business occupancies in which the maximum occupant load is 25 or fewer.

This change reflects how small facilities often operate, whereby the separation in restrooms is not based on gender but on employees and customers. This would include facilities where employees may be dirty (auto repair garage), where customers may be sick (doctor's offices), and where security or safety dictates a separation (police station). This will also better accommodate facilities that do have a gender imbalance (most doctor's offices are staffed primarily by women).

One should note that this revision has already been incorporated in IPC 2018.

Completed forms may be e-mailed to ra-uccrac@pa.gov or mailed to:
Bureau of Occupational & Industrial Safety
Department of Labor and Industry
651 Boas Street, Room 1613
Harrisburg, PA 17121

	RAC Use Only	
Submission Method:	Public Hearing: E-Mail:	Date Received: