

Suggested Modification: Dehumidification sized to provide 70 pints (33 liters) of moisture removal per day for every 1,000 square feet (93m²) or *crawl space* floor area. in accordance with the manufacturer's specifications.

Reason: This proposed modification is a 2021 submitted code section correction (RB 177-19) by the same commentator that proposed the 2018 change. Rating standards for moisture removal per day are changing (DOE) and moisture performance curves differ for different installations and entering air condition from manufacture to manufacturer. It was approved by the code development committee and no public comment was received. It will be included in the 2021 IRC.